



ILLINOIS ENVIRONMENTAL PROTECTION AGENCY

1021 North Grand Avenue East, P.O. Box 19276, Springfield, Illinois 62794-9276 • (217) 782-2829
James R. Thompson Center, 100 West Randolph, Suite 11-300, Chicago, IL 60601 • (312) 814-6026

PAT QUINN, GOVERNOR

DOUGLAS P. SCOTT, DIRECTOR

217/782-1724

January 12, 2010

Joseph Loiacono, Director Business Development
Sanexen Environmental Services Inc.
1471 Lionel-Boulet Boulevard, Suite 32
Varenes, Quebec, Canada J3X 1P7

Re: Sanexen – Aqua-Pipe Structural Water Main Rehabilitation

Dear Mr. Loiacono:

We have reviewed the product information that has been submitted to the Illinois EPA in regards to the subject referenced above. Based upon our review of that information, it appears that this product is acceptable for submission to the Illinois EPA, Division of Public Water Supplies, Permit Section on construction permit applications for future water main rehabilitation projects.

In addition to the Agency's construction permit application forms, project plans, and contract documents (if applicable), a detailed set of specifications that include specific information on the materials and testing requirements for both the temporary water main piping and the Aqua-Pipe liner materials will be required for each project.

Please be advised that the following regulations and/or standards shall apply to all water main rehabilitation projects using the Aqua-Pipe structural water main rehabilitation process: Title 35, Subtitle F, Chapter II; Recommended Standards for Water Works; ANSI/NSF 61, and the AWWA Standards.

If you have any questions please contact Michael P. Hayes at the telephone number or address referenced above.

Sincerely,

Jerry H. Kuhn, P.E.
Manager, Permit Section
Division of Public Water Supplies

cc: Dave McMillan
Michael P. Hayes